Occoquan Elementary School Replacement

Community Meeting

Building Design and Net-Zero Update October 10, 2023





- Prince William County Public Schools
- Architect: Perkins Eastman
- ➢ MEP: CMTA
- Civil Engineer: IMEG
- Foodservice Design: Nyikos Garcia



- Summer 2022: Design start
- Summer 2023: Permitting
- Winter 2023-24: Advertise project for construction bids
- Spring 2024: Start construction
- > Winter 2025-26: School facility construction complete
- Summer 2026: Site construction complete

School Aerial





Site Plan Overlay





Site Plan





Front Perspective





Site Perspective





First Floor Plan



0



Second Floor Plan





Third Floor Plan







Interior Concept





NATURE

Building Perspectives









Building Perspectives







Sustainable School Stats

- Energy projections
 - ✓ Energy use avoidance: 50% compared to typical ES
 - ✓ Target EUI: 24
- Green building aspects
 - ✓ Pursuing minimum LEED Silver
 - ✓ Utilizing PWCS' "Sustainable Design **Principles for High-Performance** Buildings"

SUSTAINABLE DESIGN PRINCIPLES For High-Performance Buildings Site EUI by Building Types Building types match the definitions found in the Commercial Building Energy Consumption Survey (CBECS). Site EUI maximums are identified in the following table The principles in this section specify requirements for energy efficiency within all new Site EUI by Building Types uction and improvements to existing buildings and the built env Education (High Sc 2 Education (Middle Sch All projects shall take into consideration the Third-Party Certifications, Benchma and Design Considerations section of this manual. In addition, all projects shall follow 3 Education (Elementary Sc Administrative the current energy code and identify which energy efficiency requirements below are applicable to the project based on project type, scope, and budget. The provisions of these Energy Efficiency principles shall be followed in all projects on existing buildings, 5 Warehouse and Stor additions, repairs, and renovations. FUII and Life-Cycle Cost Eff If there is no life-cycle cost effective combination of energy of that allows the EUI to be met, modify the design of the proposed building syste to achieve an energy consumption level at the highest level of energy efficiency that Building projects shall contain automatic control systems that have the capability to is life-cycle cost effective. In cases where the EUI is not met, the A/E shall submit reduce building equipment loads to lower electric peak demand of the building. The documentation for review and consideration by the PWCS Energy Management and Sustainability division, in collaboration with the PWCS Project Manager, PWCS Facility Management and Supervisor, Energy Management and Sustainability. building controls shall be designed with automated demand-response (DR) infrastructure capable of receiving DR requests from the school division's Building Automation Shop and automatically implementing load adjustments to HVAC. Systems shall be installed and programmed for Automated Demand Response following Prince William County Public Schools (PWCS) standards. Demand response will have two modes (occupied/ The site EUI calculation shall be derived from the proposed building performance mod unoccupied) depending on the occupancy of the building, time of day, and time of year. utilized in the life cycle cost analysis and building energy use shall be modeled following Exception: All facilities and/or equipment classified as critical shall be exempt from ASHRAF 90 1 Appendix G - Performance Rating Method with the conditions listed below this demand-response requirement. Critical can be defined as musical instrument Input Criteria: rage, art/book storage, domestic water systems, and information technology The A/E firm shall simulate the performance of the whole building and shall include the following: Utility costs – Contact PWCS Energy Management and Sustainability di Use typical meteorological year (TMY3) weather data and full-year (8760 hou analysis using NOAA historical data. Documentation Requirements:



Energy Efficiency

(MDF/Server/LAN).

Net-Zero Design Elements

- Building solar orientation on site
- Daylighting
- Indoor Environmental Quality (IEQ)
- HVAC mechanical 96 geothermal wells
- Solar array
 - ✓ 680 kW system
 - ✓ 900 MWh per year projected output
- Estimated emissions reduction is 306 metric tons of CO₂; 0.53% of division's emissions



Using the Building as a Teaching Tool



- Interactive dashboards
 - $\checkmark\,$ Accessible in classrooms via website
- Visible mechanical systems with educational signage
- Energy usage/generation indicators
- Indoor/outdoor learning spaces with educational signage



